

Kitemark™ Certificate

This is to certify that:

Peak Pipe Systems Limited
Smeckley Wood Close
Chesterfield Trading Estate
Chesterfield
S41 9PZ
United Kingdom

Holds Certificate Number:

KM 676129

In respect of:

GIS/PL2-2

Polyethylene pipes and fittings for natural gas and suitable manufactured gas Part 2: Pipes for use at pressures up to 5.5 bar

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:

Frank Lee, Product Certification Technical and Compliance Director

First Issued: 2018-04-16

Effective Date: 2021-06-09

Latest Issue: 2021-06-09

Expiry Date: 2024-04-15

Page: 1 of 2



...making excellence a habit.™

Kitemark™ Certificate

No. KM 676129

GIS/PL2-2:2016 - Polyethylene pipes and fittings for natural gas and suitable manufactured gas Part 2: Pipes for use at pressures up to 5.5 bar

Product Details & Nominal Sizes	Material	SDR / MOP
PE80 Yellow Pipe 20, 25, 32, 63mm – PPS2	Ineos Eltex Tub 172 or Borealis Borsafe ME 3441	SDR11 / 5.5 bar
PE80 Co-extruded Yellow Pipe 90, 125, 180, 225, 250, 315, 355 mm – PPS1	Black Borealis Borsafe ME 3440 Yellow Borealis Borsafe ME 3441	SDR11 / 5.5 bar SDR17.6 / 3 bar SDR21 / 2 bar
PE80 Co-extruded Yellow Pipe 90, 125, 180 mm – PPS2	Black Borealis Borsafe ME 3440 Yellow Borealis Borsafe ME 3441	SDR11 / 5.5 bar SDR17.6 / 3 bar SDR21 / 2 bar
PE100/PE80 Co-extruded Yellow Pipe 90, 125, 180, 225, 250, 315, 355 mm – PPS1	Black Borealis BorSafe HE3490-LS Yellow Borealis Borsafe ME 3441	SDR11 / 5.5 bar SDR17.6 / 3 bar SDR21 / 2 bar
PE100/PE80 Co-extruded Yellow Pipe 90, 125, 180 mm – PPS2	Black Borealis BorSafe HE3490-LS Yellow Borealis Borsafe ME 3441	SDR11 / 5.5 bar SDR17.6 / 3 bar SDR21 / 2 bar

Manufacturing location: PEAK P-0047646751-000

PPS1: Peak Pipe Systems Limited

PPS2: Production at Buxoplas Limited and all finish goods testing and dispatch at Peak Pipe Systems Limited

All pipe is supplied under the Peak Pipe brand

Note: This certificate supersedes that dated 30th March 2021 and covers the addition of PE100/PE80 co-extruded pipe.

First Issued: 2018-04-16

Latest Issue: 2021-06-09

Effective Date: 2021-06-09

Expiry Date: 2024-04-15

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).