# Kitemark™ Certificate

This is to certify that:

Simona Peak Pipe Systems Limited
Smeckley Wood Close
Chesterfield Trading Estate
Chesterfield
S41 9PZ
United Kingdom

Holds Certificate Number: KM 676129

In respect of:

**GIS/PL2-2**
**Polyethylene pipes and fittings for natural gas and suitable manufactured gas Part 2: Pipes for use at pressures up to 5.5 bar**

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:

Shahm Barhom, Group Product Certification Director

First Issued: 2018-04-16
Latest Issue: 2026-11-16

Effective Date: 2026-11-16
Expiry Date: 2029-11-07



This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated online.

BSI Assurance UK Limited, registered in England under number 7805321 at Seventh and Eighth Floors, The Acre, 90 Long Acre, London, WC2E 9RA, UK.
A member of BSI Group of Companies.

# Kitemark™ Certificate

No. KM 676129

**GIS PL2-2:2022 Polyethylene pipes and fittings for natural gas and suitable manufactured gas Part 2: Pipes for use at pressures up to 5.5 bar**

**PP1547:2022 Controls and ancillaries for use with Hydrogen**

| **Product Details & Nominal Sizes** | **Material** | **SDR / MOP** |
|---|---|---|
| PE80 Yellow Pipe<br>20, 25, 32, 63mm<br>– PPS2 | Ineos Eltex Tub 172 or<br>Borealis Borsafe ME 3441 | SDR11 / 5.5 bar |
| PE80 Co-extruded Yellow Pipe<br>90, 125, 180, 225, 250, 315, 355 mm<br>– PPS1 | Black Borealis Borsafe ME 3440<br>Yellow Borealis Borsafe ME 3441 | SDR11 / 5.5 bar<br>SDR17.6 / 3 bar<br>SDR21 / 2 bar |
| PE80 Co-extruded Yellow Pipe<br>90, 125, 180 mm<br>– PPS2 | Black Borealis Borsafe ME 3440<br>Yellow Borealis Borsafe ME 3441 | SDR11 / 5.5 bar<br>SDR17.6 / 3 bar<br>SDR21 / 2 bar |
| PE100/PE80 Co-extruded Yellow Pipe<br>90, 125, 180, 225, 250, 315, 355 mm<br>– PPS1 | Black Borealis BorSafe HE3490-LS<br>Yellow Borealis Borsafe ME 3441 | SDR11 / 5.5 bar<br>SDR17.6 / 3 bar<br>SDR21 / 2 bar |
| PE100/PE80 Co-extruded Yellow Pipe<br>90, 125, 180 mm<br>– PPS2 | Black Borealis BorSafe HE3490-LS<br>Yellow Borealis Borsafe ME 3441 | SDR11 / 5.5 bar<br>SDR17.6 / 3 bar<br>SDR21 / 2 bar |

**Manufacturing location:** PEAK P-0047646751-000

PPS1: Simona Peak Pipe Systems Limited
PPS2: Production at Buxoplas Limited and all finish goods testing and dispatch at Simona Peak Pipe Systems Limited
All pipe is supplied under the Simona Peak Pipe brand

First Issued: 2018-04-16
Latest Issue: 2026-11-16

Effective Date: 2026-11-16
Expiry Date: 2029-11-07



This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated online.

BSI Assurance UK Limited, registered in England under number 7805321 at Seventh and Eighth Floors, The Acre, 90 Long Acre, London, WC2E 9RA, UK.
A member of BSI Group of Companies.